

ontinental Foundations

Govt. Approved Valuers (A-15278)

Regd. Structural Engineers

PMC Consultants

Office: 1059, Sector 43-B, Chandigarh | E-mail: Contfound@gmail.com Mob.: 94170-18335, 98885-18335 | Telefax : 0172-4677059

GSTIN: 04AGVPB020AE2Z2

CF/1510

DATED: 11-01-2024

TO WHOM MAY IT CONCERN

It is certified that I have personally inspected School Building of "Shishu Niketan Public School Sector 43 A, Chandigarh". The inspection was carried out along with the Director of school Dr. Ashish Sharma.

The school comprises of 2 blocks. Block A: Senior Wing (constructed with Basement + 4 Storied) and Block B: Junior Wing (constructed with Basement + 2 Storied). The Building is constructed as per old Codal provisions.

The Tentative covered area of existing school building is 48117 Sft on a plot area of 11054 SqYds. On the visual inspection there were no major structural/deflection cracks observed. Minor cracks had appeared on the Junction of RCC Slab and brickwork, which the management was intimated. Rebound hammer tests and Ultrasonic pulse velocity was also carried out to determine the strength of concrete.

The building is fit for habitable use and running a school building. The approximate life of the building is 40 years with proper maintenance and retrofitting. The validity of this certificate is one year.


For Continental Foundations

(VIKAS BHARDW



SHISHU NIKETAN PUBLIC SCHOOL

BLOCKS: A SENIOR WING (CONSTRUCTED WITH BASEMENT + 4 STORIED)



SHISHU NIKETAN PUBLIC SCHOOL

BLOCKS: B JUNIOR WING (CONSTRUCTED WITH BASEMENT + 2STORIED)

ms Bu

